



ELBZ7.E364502 - CORD SETS AND POWER-SUPPLY CORDS CERTIFIED FOR CANADA

Cord Sets and Power-supply Cords Certified for Canada

See General Information for Cord Sets and Power-supply Cords Certified for Canada

YUYAO SIJI WIRE INDUSTRY CO LTD

NO. 1 ZHONGXIN RD
YUNLOU VILLAGE, MAZHU TOWN
YUYAO, ZHEJIANG 315452 CHINA

E364502

Cord sets-Power supply cords

| Cat. No. | ANSI/NEMA WD6 Config | Cord AWG | Cord Type | Electrical Rating Amps V |
|----------|-------------------------|-------------|---|-----------------------------|
| SJ-A | 1-15P | 18/2 | SPT-1, SPT-2, HPN, SVT, SJT, SJTW | 10/125 |
| | | 16/2 | SPT-2, HPN, SVT, SJT, SJTW | 13/125 |
| | | 14/2 | SJT | 15/125 |
| SJ-B | 5-15P | 18/3 | SPT-1, SPT-2,SPT-3, SVT, SJT, SJTW , STW, HPN | 10/125 |
| | | 16/3 | SPT-2,SPT-3, SVT, SJT, SJTW, STW, HPN | 13/125 |
| | | 14/3 | SPT-3, SJT, SJTW, HPN | 15/125 |

General-use extension cord set, Cat. No. 123.

Repackaged bulk power-supply cords

Last Updated on 2018-07-25

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"